# 5006+

UK	USER GUIDE WIREFREE CONTROL PANEL
F	GUIDE UTILISATEUR CENTRALE D'ALARME RADIO
E	GUÍA DEL USARIO CENTRAL INALAMBRICA
<u> </u>	MANUALE UTENTE CENTRALE RADIO
NL	GEBRUIKERSHANDLEIDING DRAADLOOS CONTROLEPANEEL







(???? = four digit user ) code







#### **TO FULL SET**

Key in your user code and press  $\widehat{\boxplus}$  (or press  $\widehat{\bullet}$  on the 525r remote setting device). The exit tone starts. Leave the premises by the designated exit route. The exit tone stops after a preset time. The alarm system is then set.

#### TO PART SET

To set your alarm system so that you can move around part of the area normally covered by detectors:

Key in your user code and press \(\frac{\text{A}}{2}\). The panel lights all the zones that will work in part set. Key in the numbers of the zones you want to switch on or off. Press \(\frac{\text{A}}{2}\) when you have finished. The exit tone starts. Leave the protected area. The tone stops after a preset time. The system is then set. The panel remembers the zones you selected for part set. The next time you want to part set, enter your user code, press \(\frac{\text{A}}{2}\) and then \(\frac{\text{A}}{2}\). The system sets after sounding the exit tone.

(If you have a 525r remote setting device, press **!**. The panel part sets in 3 seconds.)

Note: The installer may have disabled the part set facility. Contact them if you have any difficulty.

#### IF THE SYSTEM WILL NOT SET


If you are setting or part setting the system, but the panel gives an interrupted tone and zone lights are on, then one or more detectors are being triggered. Check that doors and windows are closed and there is no movement in areas covered by movement detectors.

Try to set the system again. If the fault persists call the installer.

#### TO SWITCH OFF

Enter by the designated entry route. The entry tone starts. Go to the control panel and key in your four digit user code (or press no your 525r remote setting device). The system switches off.

Why is the panel beeping? If the panel starts "beeping" once a second after you have switched off using your remote setting device then there has been an alarm while you were out. The lights on the panel indicate the cause of the alarm. Press ← to silence the tone.



#### **AFTER AN ALARM**

**Fire Alarm:** The system gives a fire alarm by sounding a continuous tone from the internal sounder, if you have a smoke detector.

- 1. Evacuate the premises and call the Fire Brigade. Do not attempt to unset the alarm.
- 2. When the premises are safe, silence the alarm and reset the sytem.

**Intruder Alarm:** The panel gives a warbling tone from its internal sounder, and triggers the external bell and strobe (if you have one).

**Tamper Alarm:** If the panel gives an internal alarm while on Standby then go to the control panel. The tamper light will be on. Call the installer for service.

#### To Silence an Alarm

Go to the panel, key in your user code. The panel stops the tone and switches off the external bell/ strobe. The lights on the panel indicate the cause of the alarm.

#### To Reset The System

Press ←. The panel goes to Standby. If the panel does not go to Standby, call the installer.

Why does the panel beep occasionally? The panel gives five short beeps once a minute to call attention to a fault. The lights on the panel indicate the cause of the alarm: a low battery (either in a detector or in the panel itself), a mains failure, or R.F. trouble. Press ← to silence the tone and then contact your installer.

#### TO CHANGE YOUR USER CODE

Your new code can be any four digit code not starting with 0 (zero).

Enter your existing user code and press 2. The first four zones light.

Enter your existing user code <u>again</u>. The zone lights go out as you enter the code. After the last digit the panel gives a double bleep and lights the bottom four zones.


Enter your new user code. The zone lights go out as your enter the new code. The panel gives a double bleep when it accepts the new code.




Check the premises









### : 0+999+0

Walk past detectors



## 

#### TO READ THE LOG

Your alarm system keeps a record of the last 16 alarm events.

Enter your user code and press  $\ \square$ . The panel lights show the last event.

Press  $\square$  repeatedly to see earlier alarms. The panel gives a low tone when you reach the end of the log. Press  $\leftarrow$  at any time to leave the log.

#### TO WALK TEST THE DETECTORS

Enter your user code and press ... The Standby light flashes.

Activate each detector in turn. The panel gives a short double bleep and briefly lights the corresponding zone when it receives a signal from a detector. When you have checked all the detectors press  $\leftarrow$ . The panel returns to Standby.

Note: Make sure the movement detectors do not see any movement for three minutes before starting the walk test.

#### TO TEST BELLS

Enter your user code and press 5. The panel sounds the external bell. Press ← to switch the bell off

Enter your user code and press 4. The panel flashes the strobe. Press ← to switch the strobe off.

Scantronic Scan House Xerox Business Park Mitcheldean Gloucestershire GL17 OSN ENGLAND Tel: +44 (0)1594 543343 Fax: +44 (0)1594 544136

Scantronic Nieuwe Haven 11 3311 AP Dordrecht NEDERLAND Tel: +31 (0)78 6134888 Fax: +31 (0)78 6134343

Scantronic 5 Avenue del Villa Antony 94410 Saint Maurice FRANCE Tel: +33 (0)1 49 76 00 71 Fax: +33 (0)1 49 76 00 58 Scantronic Spain S.A.
Dist. Oficial J.M. Systems-Com, S.A c/ Llanterners, 7
Pol. D'Obradors
46110 GODELLA
VALENCIA
ESPAÑA
Tel: +34 (9)6 363 97 08
Fax: +34 (9)6 390 38 72
BBS. +34 (9)6 364 50 00

Scantronic by Si-Tronic Via S. Allende 12/14 20091 Bresso -MI-ITALIA

TEL: +39 (0)2 66 500 073 FAX: +39 (0)2 61 40 557