



એકલવ્ય મોડેલ રેસિડેન્શિયલ સ્કૂલ, તિલકવાડા

મહાત્મા ગાંધી ગ્લોબલ ઇન્ડિયન એકલવ્ય સ્કૂલ
(છ.એસ.ટી.ઇ.એસ, ગાંધીનગર ધ્વારા અનુદાનિત અને ગ્લોબલ ઇન્ડિયન ફાઉન્ડેશન સિંગાપુર ધ્વારા સંચાલિત)

એસ.એસ.સી. ઇન્ડેક્સ નં. ૭૬.૦૬૪

Registered as E.M.R.S. No. 23/982/87
એસ.એસ.સી. ઇન્ડેક્સ નં.(૧૫૨૨૯) ૨૬.૦૩૦

એસ.એસ.સી. ઇન્ડેક્સ નં. (સચબા) ૨૬.૦૩૪ (બી)

Letter No./EMRST/ADM/2021-22/242

Date: 07.06.2021

પ્રતિ,
જિલ્લા શિક્ષણાધિકારીશ્રી
જિલ્લા શિક્ષણાધિકારીશ્રીની કચેરી,
રાજપીપળા.

વિષય: ફાયર (એન. ઓ. સી) ચેકલીસ્ટ બાબત.

માનનીય સાહેબશ્રી,

જયભારત સાથે ઉપરોક્ત વિષય અન્વયે સવિનય જાણાવવાનું કે, એકલવ્ય મોડેલ રેસિડેન્શિયલ સ્કૂલ, તિલકવાડા માં તમામ બિલ્ડિંગ્સની ઉંચાઈ ૮ મીટર થી ઉપર ન હોવાથી, અર્બન ડેવલપમેન્ટ અને અર્બન હાઉસિંગ ડિપાર્ટમેન્ટ સૂચના નંબર GH/V/9 of 2021/AGN/-102021-100-I-1. Dated:- 22 January -2021, અનુસાર ફાયર એન.ઓ.સી જરૂરી નથી જો કે આગ સલામતીના હેતુ માટે શાળા જરૂરીયાતનું ચુસ્તપણે પાલન કરે છે. શાળામાં જરૂરિયાત મુજબ ફાયર સેફ્ટી ના બોટલ દરેક બિલ્ડિંગ માં લગાવેલ છે જે આપની જાણ સારું.

આભાર,

આચાર્ય,

વિમલ સી. મહેતા

આચાર્ય

એકલવ્ય મોડેલ રેસિડેન્શિયલ સ્કૂલ (કે.પુ.)

તિલકવાડા, જી. નર્મદા.



EKLAVYA MODEL RESIDENTIAL SCHOOL, TILAKWADA
(MAHATMA GANDHI GLOBAL INDIAN EKLAVYA SCHOOL)
MANAGED BY G.S.T.E.S., GANDHINAGAR & G.I.F., SINGAPORE
Registered as E.M.R.S. No. 23/982/87
H.S.C. Index no.(Gen) 28.030

S.S.C. Index no.78.064

H.S.C. Index no.(Sc.) 28.034 (B)

Date: 07.06.2021

Letter No./EMRST/ADM/2021-22/241


Declaration Regarding Fire Protection System

We hereby declare that our school building / educational building is situated at (address) School Name: Eklavya Model Residential School, Tilakwada, village: - Gansinda, Tal:- Tilakwada, Dist:-Narmada.

We hereby declare that our building height is 9 meters which is not above 9 meters. So fire NOC is not required as per URBAN DEVELOPMENT AND URBAN HOUSING DEPARTMENT notification number GH/V/9 of 2021/AGN/-102021-100-I-1. Date:- 22 January -2021, However for the fire safety purpose we have strictly followed the requirement of NATIONAL BUILDING CODE OF INDIA PART-4 FIRE AND SAFETY, We have provided in our building Fire Protection System as mentioned below which is as per requirement of NATIONAL BUILDING CODE OF INDIA PART-4 FIRE AND SAFETY.

- 1.
- 2.
- 3.
4. Fire Safety bottle is available in the school.
- 5.


Date: 07.06.2021


Signature with Stamp

PRINCIPAL
M.G.G.I.E.S.(E.M.R.S.)TILAKWADA



At - Gansinda, TA & PO:-Tilakwada-391120, Dist:-Narmada, Gujarat, India
Tel.No.02661-266191, 144, LL.Mob.7698981815. Email ID: eklavyaschooltilakwada@yahoo.in


07/06/2021



GUJARAT FIRE SAFETY CORPORATION

Date : 02/01/2021

Certificate

DATE : 3/01/2021

EXPIRE : 02/01/2022

TYPES : 06 KG ABC TYPE FIRE EXTINGUISHER REFILLING(16 Nos)

LOCATION : MAHATMA GANDHI GLOBEL INDIAN EKLAVYA SCHOOL TILAKVADA.

THE ABOVE MENTIONED GOODS ARE WARRANTED AGAINST
DEFECT IN MATERIAL AND WORKMANSHIP UNDER NORMAL USE.
THE WARRANTY IS LIMITED TO PERIOD OF TWELVE MONTH
FROM COMMISSIONING.

FOR GUJARAT FIRE SAFETY CORPORATION



FOR REFILLING CALL: 90991 79517 / 97256 72261.

GST IN - 24BNRPP7524D1ZS

UAM NO- GJ24A0048962

CR NO- 19200148