

## Installation Guide for Relocatable (Toxic)

### RELOCATABLE POSITIONING AND INSTALLATION

1. Unit can be lifted by crane or forklift when empty (must not be relocated when fully loaded)
2. Location of your relocatable dangerous goods store must be according to regulatory requirements applicable, such as separation distances to protected and public places
3. Vegetation that could become a fire hazard shall be kept short
4. A safety shower and eyewash facility should be located within 7m if the packages are opened, please [click here](#) for a link to our range
5. Unit must be mounted on suitable footings, sitting level and supported under each base plate
6. If the surface is not level you may acquire [PVC packers](#) to level up the unit, ensuring all base plates are supported
7. Fix unit down using anchors (T16150GH Tru-Bolts) [Ramset Stud Anchors Installation Guide](#)
8. Ensure all doors operate smoothly



To ensure you sustain compliance you will need to periodically review your control measures and carry out maintenance.

More information can be found in the below blogs:

[Assessing off site risks to your hazardous chemical stores](#)

[SUSTAIN: 5 actions for maintaining chemical hazard controls](#)

[How to Clean the Spill Containment Sump of an Outdoor DG Store](#)

