



**REPORT NUMBER: 100953749SAT-007**  
ORIGINAL ISSUE DATE: January 29, 2013  
REVISED DATE: N/A

**EVALUATION CENTER**  
16015 Shady Falls Road  
Elmendorf, TX 78112  
Phone: (210) 635-8100  
Fax: (210) 635-8101  
www.intertek.com

**RENDERED TO**

**Alucoil North America LLC**  
**1976 Joe Rogers Jr. Blvd**  
**Manning SC 29102**

PRODUCT EVALUATED: Alucoil ACM Panels (Larson)  
EVALUATION PROPERTY: Fire Resistance

**Report of Testing Alucoil ACM Panels (Larson) for compliance with the applicable requirements of the following criteria: NFPA 285 Standard Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components, 2012 Edition.**

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*

**TEST REPORT**

## 6 Conclusion

---

Intertek Testing Services NA, Inc. (Intertek) has conducted testing for Alucoil North America LLC, on their Alucoil ACM Panels (Larson), to evaluate their fire resistance. Testing was conducted in accordance with the applicable requirements of, and following the standard methods of, **NFPA 285 Standard Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components, 2012 Edition**. This evaluation took place on January 15, 2013.

Based on the data from this test, the assembly met the conditions of acceptance of the above mentioned standards.

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

### INTERTEK TESTING SERVICES NA, INC.




Tested by:

\_\_\_\_\_  
Joseph Zatopek  
**Test Engineer**



Reported by:

\_\_\_\_\_  
Michael A Brown  
**Technical Writer**



Reviewed by:

\_\_\_\_\_  
Victor M. Burgos  
**Project Engineer, Fire Resistance**