

Caterpillar

Model No. 350 Generator - 320Kva /256Kw

Generator Model: 350
Engine Model: 3406
Engine Serial Number: 1DZ17312
Date of manufacture: 2007
Engine Hours: 25497

 Alternator Number:
 CAT00000L9ES06832

 Rating:
 350Kva / 256Kw

 Voltage:
 415 / 240 Volts

Generator MWh: 2135

Description

- Electrical panel looks complete with no missing parts
- · Governor actuator was missing but has been replaced
- Woodward controls seem ok showing hours etc
- Engine runs off main control panel and Woodward governor system works perfectly
- Missing 2 x main batteries and the battery link
- · The alternator internal condition is duty
- Voltage running 237 volts phase to neutral
- Engine condition the exhaust pipe is broken, water has been drained and refilled with water Antifreeze -13. The
 fuel line seal needs repair, sucking air into the fuel system. The filter bowl bottom is broken. Overall the engine runs
- All the locks to the canopy have been unseized and are working fine, the insulation foam inside requires replacing in areas but this does not affect the functionality. The inside has been cleaned of any heavy dust







Head Office: Church Road South, Skegness, Lincolnshire, PE25

SIMPLE

PROFITABLE

SUSTAINABLE



WWW.RAMCO.CO.UK



01754 880880



