Hardware Datasheet

Relay Unit





Manufacturers Details

Atamate Ltd
Old House
The Ridings
Oxford
OC3 8TB
UK

Tel: +44 1865 920 101 www.atamate.com

Description

The Relay Unit (RU) is a custom output unit for the Atamate home automation system. It has 6 change-over relays (SPDT) which can be supplied power from a common source or, if the relevant links are cut, can be supplied independently as 'dry contact' relays. The relays are controlled and energised by a Zone Gateway (ZG) using a CAT5/CAT6 cable and RJ45 connector. There are 4 glands for the cables to the relays.

Each relay has a manual over-ride 'ON' switch and an LED indicator to show it is ON. There is also a power supply LED indicator to show the RU is connected to a ZG and has power. The relays are designed to have minimal power consumption, and thus heat generation, by using a larger 'pull-in' current and then reducing to a smaller 'hold' current.

Connections

The RU has the following connections:

- ZG socket for connecting back to a ZG. This supplies the RU with it's power and drive signals for the relays. This is a RJ45 socket.
- 4 glands for power and output cables to the relays.

Properties

Relay - SPDT (Single Pole, Double Throw) with COMMON, N/O (Normally Open) and N/C (Normally Closed) terminals. N/O - max 6 Amp, 240Vac, 30Vdc

N/C - max 3Amp, 240Vac, 30Vdc

C - Common terminal for N/O and N/C terminals. Cuttable links to adjacent relay 'C' terminals.

N - Spare terminal for each relay, notionally a 'Neutral' terminal. Cuttable links to adjacent relay 'N' terminals. E - Spare terminal for each relay, notionally an 'Earth' terminal. All 'E' terminals are permanently linked together.

Common supply terminals are permanently linked to relay 6. Also linked to other relays if the cuttable links are left in place. June 2016 Version 1.1




Hardware Datasheet

Relay Unit



Physical Dimensions :- 215mmx150x38mm (WxLxH). Extra space needed for cable entry.

Storage :- 0 to 60C, 10 - 95%RH non-condensing Usage :- 0 to 40C, 10 - 95%RH non-condensing



June 2016 Version 1.1

